# High Precision, Remote Type, 2-color Display Digital Pressure Sensor 540/ Series P



# **Pressure Sensor Controller** Series PSE300

# Response Time **1** ms Set Pressure Resolution **1/1000**

Can be mounted in close proximity with each other either horizontally or vertically.



Connection



2 outputs + Analog output or auto shift input

## **Compact Pressure Sensor for Pneumatics** PSE Series PSE540 <sup>z</sup>SE3 PS Weight **2.9** g Dimension 9.6 x 20.8 x 18 mm <sup>Z</sup>SE<sup>1</sup> ZSP Pads can be directly Manifolding is mounted. ISA2 possible **IS** ZSM PF2□ IF□ Data

# Pressure Sensor for **General Purpose Fluids** Series PSE560

# I*IP65* Wetted Material Stainless steel 316L

Copper-free • Oil-free (Single diaphragm)



ZSE□ ISE□

## Variations



- Anti-chattering function

Se	ries		Rat	ed pressure ran	ge		
	PSE541	0 to –101 kPa	Vacuum	–101 kPa	0		
For prieumatics	PSE543	–100 to 100 kPa	Compound pressure	–100 kPa		100 kPa	
	PSE560	0 to 1 MPa	Positive pressure		0		🖒 1 MPa
For general	PSE561	0 to –101 kPa	Low pressure	–101 kPa	0		
purpose fluids	PSE563	-100 to 100 kPa	Compound pressure	–100 kPa		100 kPa	
	PSE564	0 to 500 kPa	Positive pressure		0	√ 500 kPa	



# 

# **Pressure Sensor For General Fluids** Series PSE560



ŝŜ	Insulation resistance	50 M $\Omega$ between live parts and case (at 50 VDC)
ď	Vibratian registence	10 to 150 Hz at whichever is smaller of 1.5 mm amplitude or 20 m/s <sup>2</sup> acceleration,
	Vibration resistance	in X, Y, Z directions, for 2 hours each (De-energized)
	Impact resistance	500 m/s <sup>2</sup> in X, Y, Z directions, 3 times each (De-energized)
Temp	perature characteristics	±2% F.S. or less (0 to 50°C, based on 25°C), ±3% F.S. or less (–10 to 60°C, based on 25°C)

#### **Piping Specifications**

	Model	01	02	N01	N02	C01	A2	B2
Dort cizo		R 1/8	R 1/4	NPT 1/8	NPT 1/4			TO 1 1/4
FUILSIZE		M5 x 0.8	M5 x 0.8	M5 x 0.8	M5 x 0.8	RC I/8	UNJ 1/4	4 I SJ 1/4
Material		Case: C3604 + nickel plated, Piping port/pressure sensor: Stainless steel 316L						
Capacitachia		PSE56□-□: Oil proof 3-wire heavy-duty vinyl cable with air tube (0.2 mm <sup>2</sup> )						
	able	PSE56□-□-28: Oil proof 2-wire heavy-duty vinyl cable with air tube (0.2 mm <sup>2</sup> )						
Weight -	With sensor cable	193 g	200 g	194 g	201 g	187 g	203 g	193 g
	Without sensor cable	101 g	108 g	102 g	109 g	95 g	111 g	101 g



# Series **PSE560**

## **Internal Circuit**







## Dimensions

## PSE56 - 01/02 / PSE56 - N01/N02



\* The dimensions of Part C are common to all PSE56 models.

#### PSE56□-C01



Model	Α	В
PSE56□-01	8.2	R 1/8
PSE56□-02	12	R 1/4
PSE56□-N01	9.2	NPT 1/8
PSE56□-N02	12.2	NPT 1/4

\_

15.5

9.5

Rc 1/8

URJ 1/4

TSJ 1/4

PSE56D-C01

PSE56□-A2

PSE56□-B2

#### PSE56□-A2





PS	E5	<b>6</b> [	]-	<b>B2</b>





Series **PSE Specific Product Precautions 1** 

Be sure to read before handling.

## Pressure Sensor

Handling

## 🗥 Warning

- 1. Do not drop, bump, or apply excessive impact (PSE540: 980 m/s<sup>2</sup>, PSE560: 500 m/s<sup>2</sup>) while handling. Although the body of the sensor may not be damaged, the inside of the sensor could be damaged and lead to malfunction.
- 2. The tensile strength of the cord is 50 N. Applying a greater pulling force to it can cause malfunction. When handling, hold the body of the sensor-do not dangle it from the cord.
- 3. Do not use pressure sensors with corrosive and/or flammable gases or liquids.
- 4. Connection of sensor connector Sheath • Cut the sensor cable as illustrated to the right.
  - · Referring to the table below, insert each lead wire of the cable at the position marked with a number corresponding to the color of the lead wire.

Connector	Wire co	re color
no.	For PSE200 (ZS-26-E)	For PSE300 (ZS-28-C)
1	Brown (DC (+))	Brown (DC (+))
2	Black (OUT: 1 to 5 V)	Not connected
3	Blue (DC (-))	Blue (DC (-))
4	Not connected	Black (OUT: 1 to 5 V)

- · Confirm that the numbers on the connector match the colors of the wires and that the wires are inserted to the bottom. Press Part A by hand for temporary fixing.
- · Press in the central part of Part A vertically with a tool such as pliers.
- A sensor connector cannot be taken apart for reuse once it is crimped. If the wire arrangement is incorrect or

if the wire insertion fails, use a new sensor connector.

• For connection to SMC Series PSE300 pressure switches, use sensor connectors (ZS-28-C) or e-con connectors listed below.

Manufacturer	Part no.
Sumitomo 3M	37104-3101-000FL
Tyco Electronics AMP	1-1473562-4

· For detailed information about e-con connectors, please consult the manufacturers of the respective connectors.

## **Operating Environment**

# \land Warning

- 1. The pressure sensors are CE marked; however, they are not equipped with surge protection against lightning. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. The pressure sensors do not have an explosion proof rating. Never use pressure sensors in the presence of flammable or explosive gases.

### Air Supply

## 1. Use of toxic, corrosive or flammable gases

Since the switch uses stainless steel 316L as the material of the pressure sensor and fittings, do not use toxic or corrosive gases.

#### 2. Fluid compatibility

\land Warning

Since the switch uses stainless steel 316L as the wetted material (for the pressure sensor and fittings), use fluids that will not corrode this material.

(For the corrosiveness of the fluids, please consult with the manufacturers of the respective fluids.)

#### Helium leakage test

Helium leakage test is conducted on the welded parts. Use ferrules by Crawford Fittings (Swagelok® fittings) as TSJ fittings, seals and glands by Cajon (VCR® fittings) as URJ fittings. If ferrules, seals, or glands of other brands are to be used, be sure to conduct helium leakage test before using those products.

## Controller

Handling

# \land Warning

- 1. Do not drop, bump, or apply excessive impact (100 m/s<sup>2</sup>) while handling. Although the body of the controller case may not be damaged, the inside of the controller could be damaged and cause malfunction.
- 2. The tensile strength of the power supply/output connection cable is 50 N; that of the pressure sensor lead wire with connector is 25 N. Applying a greater pulling force than the applicable specified tensile strength to either of these components can lead to malfunction. When handling, hold the body of the controller-do not dangle it from the cord.

#### Connection

## \land Warning

- 1. Incorrect wiring can damage the switch and cause malfunction or erroneous switch output. Connections should be done while the power is turned off.
- 2. Do not attempt to insert or pull out the pressure sensor or its connector when the power is on. Switch output may malfunction.
- 3. Wire separately from power lines and high voltage lines, avoiding wiring in the same conduit with these lines. Malfunctions may occur due to noise from these other lines.
- 4. If a commercial switching regulator is used, make sure that the F.G. terminal is grounded.

ZSE□ ISE□
PSE
<sup>z</sup> SE3
PS
${}^{Z}_{I}\mathbf{SE}^{1}_{2}$
ZSP
ISA2
IS□
ZSM
PF2□
IF□
Data

Part-A

20 mm or more

Insulator



Series PSE Specific Product Precautions 2

Be sure to read before handling.

## Controller

**Operating Environment** 

## \land Warning

- 1. Our pressure sensor controllers are CE marked; however, they are not equipped with surge protection against lightning. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. Our pressure sensor controllers do not have an explosion proof rating. Never use pressure sensors in the presence of flammable or explosive gases.
- 3. Enclosure "IP65" applies only to the front face of the panel when mounting. Do not use in an environment where oil splashing or spraying is anticipated.

#### Mounting

## **A** Caution

#### 1. Mounting with bracket

Mount the bracket on the body with two M3 x 5L mounting screws.

Tighten the bracket mounting screws at a tightening torque of 0.5 to 0.7  $N{\cdot}m.$ 



#### 2. Mounting with panel mount adapter

Secure the panel mount adapter with two M3 x 8L mounting screws.



### Mounting

#### 3. Panel mount adapter removal

**A**Caution

To remove the controller with panel mount adapter from the equipment, remove the two mounting screws, and pull out the controller while pushing the claws outward.

Failure to follow this procedure can cause damage to the controller and panel mount adapter.



Wiring

# **A** Caution

#### 1. Connection and removal of sensor connector

- Hold the lever and connector body with two fingers and insert the connector straight into the pin until it is locked with a click sound.
- To remove the connector, pull it out straight while pressing the lever with one finger.



#### 2. Connector pin numbers for power supply/output cable







Series PSE Specific Product Precautions 3

Be sure to read before handling.

#### **Regulating Pressure Range and Rated Pressure Range**

# **A** Caution

#### Set the pressure within the rated pressure range.

The regulating pressure range is the range of pressure that can be set on the controller.

The rated pressure range is the range of pressure that satisfies the specifications (accuracy, linearity, etc.) of the sensor.

Although it is possible to set a value outside the rated pressure range, the specifications will not be guaranteed even if the value stays within the regulating pressure range.

Sensor				Press	ure range	
		–100 kPa	u 0	100 kPa	500 kPa	1 MPa
For vacuum	PSE541 PSE561	–101 kPa –101 kPa	0 k	Pa 0 kPa		
For compound pressure	PSE543 PSE563	–100 kPa –101 kPa		100 kPa 101 kPa		
For positive	PSE560	–100 kPa (-0.1 MPa)	0			1 MPa 1 MPa
pressure	PSE564	-50	0 kPa		500 kPa 500 kPa	

Rated pressure range of sensor Regulating pressure range of controller

Data

ZSE□ ISE□

PSE