


How to Order Manifold

Type 45G (Flat cable, PC wiring system compatible)



For special specifications, indicate separately on the manifold specification sheet.

Both sides


2 to 16 stations


Special specifications

В

M

Manifold Specifications





Note 1) For more than 11 stations, supply pressure to P port on both sides and exhaust from R port on both sides. Note 2) There is a limit depending on the number of solenoids. Refer to "How to Order".


Flow Characteristics

	Port	size	Flow characteristics						
Model	1, 5, 3	4, 2	1	\rightarrow 4/2 (P \rightarrow A/	B)	$4/2 \rightarrow 5/3 \text{ (A/B} \rightarrow \text{EA/EB)}$			
(P, EA, EB) (A, B)		C (dm3/(s·bar))	b	Cv	C (dm3/(s·bar))	b	Cv		
SS5Y3-45□	C8	C6	0.88	0.21	0.22	0.95	0.18	0.22	
SS5Y5-45□	C10	C8	2.2	0.24	0.53	2.5	0.18	0.58	

Manifold Option

Blanking plate assembly

Terminal block



Series	Assembly part no.					
SY3000	SX3000-75-2A					
SY5000 SX5000-76-2A						
○ N						

Note) • When mounting blanking plate, be sure to mount a short cap. Two stations are

necessary for the double, 3 position (Dual body type).

■SUP block disk

By installing a SUP block disk in the pressure supply passage of a manifold valve, it is possible to supply two or more different high and low pressures to one manifold.



Series	Part no.
SY3000	SX3000-77-1A
SY5000	SX5000-77-1A

■ EXH block disk

By installing an EXH block disk in the exhaust passage of a manifold valve, it is possible to divide the valve's exhaust so that it does not affect another valve. (Two block disks are needed to divide both exhausts.)



Series	Part no.
SY3000	SX3000-77-1A
SY5000	SX5000-77-1A

Series	Part no.			
SY3000	SX3000-77-1A			
SY5000	SX5000-77-1A			

∕!\ Caution

Mounting screw tightening torques

M2: 0.17 N·m M3: 0.8 N·m M4: 1.4 N·m

Label for block disk

The labels shown below are used on manifold stations containing SUP/EXH block disk(s) to show their location. (3 pcs. each)

VZ3000-123-1A (In common with SY3000/5000)

Label for SUP block disk Label for EXH block disk Label for SUP/EXH block disk



Note) The value is for manifold base with 5 stations and individually operated 2 position type.






SV

SZ

SYJ

SX


Note) When a block disk is concurrently ordered by specifying on the manifold specification sheet, etc., a label will be stuck on the position where block disk is mounted.



Series	Model	Effective area	Α	В	С
For SY3000 (Ø8)	AN203-KM8	14 mm ²	ø16	26	51
For SY5000 (Ø10)	AN200-KM10	26 mm ²	ø22	53.8	80.8
FOI 313000 (Ø10)	AN300-KM10	30 mm ²	ø25	70	97

■ Plug (white)

These are inserted in unused cylinder ports and SUP, EXH ports. Purchasing order is available in units of 10 pieces.




Dimensions

Applicable fittings size ød	Model	Α	L	D
4	KQ2P-04	16	32	6
6	KQ2P-06	18	35	8
8	KQ2P-08	20.5	39	10
10	KQ2P-10	22	43	12
1/8"	KQ2P-01	16	31.5	5
5/32"	KQ2P-03	16	32	6
1/4"	KQ2P-07	18	35	8.5
5/16"	KQ2P-09	20.5	39	10

Manifold Option

■ D-sub connector (25 pins)/Cable assembly



D-sub Connector Cable

Cable length (L)	Assembly part no.	Note
1.5 m	AXT100-DS25-015	Cable 25 core
3 m		x 24 AWG
5 m	AXT100-DS25-050	X 24 AVVG



When a commercially available connector is required, use a 25 pin female connector conforming to MIL-C24308.

Electric Characteristics

Item	Characteristics
Conductor resistance Ω/km, 20°C	65 or less
Voltage limit V, 1 min, AC	1000
Insulation resistance MΩkm, 20°C	5 or more

Note) The min. bending radius of D-sub cable assembly is 20 mm.


D-sub Connector Cable Assembly Terminal No.


i erminai no.	Lead wire color	Dot marking
1	Black	None
2	Brown	None
3	Red	None
4	Orange	None
5	Yellow	None
6	Pink	None
7	Blue	None
8	Purple	White
9	Gray	Black
10	White	Black
11	White	Red
12	Yellow	Red
13	Orange	Red
14	Yellow	Black
15	Pink	Black
16	Blue	White
17	Purple	None
18	Gray	None
19	Orange	Black
20	Red	White
21	Brown	White
22	Pink	Red
23	Gray	Red
24	Black	White
25	White	None

Connector manufacturers' example

- Hirose Electric Co., Ltd.
- Fujitsu Limited
- Japan Aviation Electronics Industry, Ltd.
- J.S.T. Mfg. Co., Ltd.

■ Flat Ribbon Cable Connector/Cable assembly





Flat Ribbon Cable Assembly

		•			
Cable length (L)	10 pins	20 pins	26 pins		
1.5 m	AXT100-FC10-1	AXT100-FC20-1	AXT100-FC26-1		
3 m	AXT100-FC10-2	AXT100-FC20-2	AXT100-FC26-2		
5 m	AXT100-FC10-3	AXT100-FC20-3	AXT100-FC26-3		
Connector width (W)	17.2	30	37.5		



* For other commercial connectors, use a type with strain relief that conform to MIL-C-83503.


Connector manufacturers' example

- Hirose Electric Co., Ltd.
- Sumitomo 3M Limited
- Fujitsu Limited
- Japan Aviation Electronics Industry, Ltd.
- J.S.T. Mfg. Co., Ltd.

■ Dimensions/DIN rail

VZ1000 − 11 − 1 − ☐ • Refer to L dimensions

 \ast Fill in \square with an appropriate no. listed on the table of DIN rail dimensions shown below.



No.	0	1	2	3	4	5	6	7	8	9	10
L Dimension	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223
No.	11	12	13	14	15	16	17	18	19	20	21
L Dimension	235.5	248	260.5	273	285.5	298	310.5	323	335.5	348	360.5
No.	22	23	24	25	26	27	28	29	30	31	32
L Dimension	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498
No.	33	34	35	36	37	38	39	40	41	42	43
L Dimension	510.5	523	535.5	548	560.5	573	585.5	598	610.5	623	635.5
No.	44	45	46	47	48	49	50	51	52	53	54
L Dimension	648	660.5	673	685.5	698	710.5	723	735.5	748	760.5	773
No.	55	56	57	58	59	60	61	62	63	64	65
L Dimension	785.5	798	810.5	823	835.5	848	860.5	873	885.5	898	910.5
No.	66	67	68	69	70	71					
L Dimension	923	935.5	948	960.5	973	985.5					





* Refer to L1 dimension on pages starting with page 1-4-150 for lengths that correspond to the number of manifold stations.

Manifold Internal Wiring

Type 45G: Flat Ribbon Cable (PC Wiring System compatible)

It's the manifold for 20 pins flat ribbon cable connector which is compliant for PC wiring system.





- The maximum number of stations that can be accommodated is 16 manifold stations, with up to 16 solenoids. (For more stations, please contact SMC.)
- Regardless of the connector mounting position, stations are to be counted from D side as the 1st one.


For details about the PC wiring system, refer to catalog CAT.ES02-20 separately.




How to Connect SS5Y□-45□ (Plug-in)

Power terminal is equipped with plug-in manifold of Series SY as standard. Power terminal enables the power supply to valve from either of manifold or controller side.

1. Wiring example when using manifold power supply terminals




2. Wiring example when not using manifold power supply terminals (Power is supplied to the controller side or along the wiring, etc.)




⚠ Caution


Single wire, COM position, etc. of PLC are different from each manufacturer. When
connecting with PLC, read the specifications carefully and understand the electrical
circuit. Poor wiring could cause damage to PLC, power source, etc. as well as manifold
and valve.



SY3000: PC Wiring System Compatible (Flat ribbon cable/Plug-in)



SY3000: PC Wiring System Compatible (Flat ribbon cable/Plug-in)



Note) The **L1** to **L4** dimensions of **SS5Y3-45GD-**Stations D-^{C4}, N3 are identical to those of SS5Y3-45GD-Stations U-^{C4}, N3.


SV


SZ

SY

SYJ


SX






Stations n	2 stations	3	4	5	6	7	8	9	10 stations
L1	123	135.5	148	148	160.5	173	185.5	198	210.5
L2	112.5	125	137.5	137.5	150	162.5	175	187.5	200
L3	91.5	102	112.5	123	133.5	144	154.5	165	175.5
L4	15.5	16.5	17.5	12.5	13.5	14.5	15.5	16.5	17.5

SS5Y3-45GD-Stations B-C4, N3








DIN Rail Manifold Exploded View

Type 45F (D-sub Connector) Manifold



Replacement Parts

	5	Part	no.				
No.	Description	SY3000	SY5000	Note			
1	Manifold block assembly			according to an attached lead wire assembly banifold block assembly part number shown belo			
2	SUP/EXH block assembly	(Metric size) SX3000-51-2A (Inch size) SX3000-51-16A	(Metric size) SX3000-51-2A (Inch size) SX5000-51-16A	Metric size Inch size SY3000: P, R port with One-touch fitting for Ø8 With One-touch fitting for SY5000: P, R port with One-touch fitting for Ø10 With One-touch fitting for			
3	End block assembly	SX3000-52-2A	SX5000-52-2A	For D side			
4	End block assembly	SX3000-53-2A	SX5000-53-2A	For U side			
⑤-1	Connector block assembly (for D-sub connector)	SX3000-64-1A	SX5000-64-1A	-1A: +COM -1NA: -COM			
⑤-2	Connector block assembly (for 26 pins flat cable)	SX3000-64- ^{2A} _{2NA} -26	SX5000-64- ^{2A} _{2NA} -26		Note)		
⑤-3	Connector block assembly (for 20 pins flat cable)	SX3000-64- ^{2A} _{2NA} -20	SX5000-64- ^{2A} _{2NA} -20	-2A: +COM -2NA: -COM	For 24 VDC		
⑤-4	Connector block assembly (for 10 pins flat cable)	SX3000-64- ^{2A} _{2NA} -10	SX5000-64- ^{2A} _{2NA} -10				
⑤-5	Connector block assembly (for 2 to 8 stations (T, T1) terminal block)	SX3000-64-3A	SX5000-64-3A	In common between +COM and -COM.			
⑤-6	Connector block assembly (for 9 to 17 stations (T1) terminal block)	SX3000-64-8A	SX5000-64-8A				
6	Round head combination screw	SY3000-23-4	M3 x 26, Matt nickel plated				
7	Gasket	SX3000-57-4	SX5000-57-6				
8	DIN rail	VZ1000-11-1-I □		Refer to pag	Refer to page 1-4-123.		

Note 1) The numbers 5-1 to 4 are for 24 VDC. For 12 VDC, suffix "-12V" to the end of parts number. (Example) SX3000-64-1A-12 V Note 2) Two manifold block assemblies are necessary for the double, 3 position (Dual body type).

Style of manifold	Manifold block assembly part no.	Note		
For 45(N)F (D-sub connector)	SX₅ ³ 000-50-3A-□□	□□: AB port SY3000 (metric size) C4: With One-touch fitting for ø4 C6: With One-touch fitting for ø6		
For 45(N) PG (Flat ribbon cable)	OV ³ 000 50 54 55	(inch size) N3: With One-touch fittign for σ 5/ ₃₂ " N7: With One-touch fitting for σ 1/ ₄ "		
For 45G PC Wiring System compatible	SX ₅ ³ 000-50-5A-□□	A, B port SY5000 (metric size) C4: With One-touch fitting for ø4 C6: With One-touch fitting for ø6 C8: With One-touch fitting for ø8		
For 45^{T}_{11} (Terminal block)	SX ₅ ³ 000-50-7A-□□	(inch size) N3: WIth One-touch fitting for σ $5^{\circ}/3^{\circ}$ N7: With One-touch fitting for σ $1^{\circ}/16^{\circ}$ N9: With One-touch fitting for σ $1^{\circ}/16^{\circ}$		



How to Increase Manifold Base

Loosen bolt (a) fixing the manifold base until it begins to turn idly. (While pressing DIN rail releasing buttons ©, at two locations, separate the manifold base from the DIN rail.)

Additional bases are to be added to the U side. Press splitting button (b) of the manifold block assembly on the U side until button (b) locks, and then separate the block assemblies.

Separate the connector block assembly in the same manner as 2, and remove the connector mounting screw shown in Fig. (1).

4 Loosen the valve mounting screw on the U side, remove the valve, and take out the receptacle housing. (Refer to Fig. (2).)


Insert the common wire (red) of the manifold block assembly to be added into the pin insertion section (N mark) of the receptacle housing that was taken out in 4, mount it on the manifold block, and mount the removed valve.


As shown in Fig. (3), mount the additional manifold block assembly on the DIN rail on the U side. Refer to the circuit diagram, and insert the lead wire (black) as shown in Fig. (4).

Press the blocks against each other until a click sound is produced, place the lead wire in the manifold block, and close the lid without pinching the lead wire.


8 While lightly holding the blocks together so that there are no gaps between them, secure them to the DIN rail by tightening

- 1. Depending on the connector, there is a limit to the number of solenoids that can be used. Manifold bases that can be added cannot exceed the number of usable solenoids.
- 2. The manifold block assembly mounting position for additional manifold bases is always on the U side, because wires are connected to respective connectors sequentially from the D side.
- 3. When bolt a for the end block is not sufficiently tightened during reassembly, air leakage may result. Before supplying air, check that there is no gap between blocks and that the manifold block is firmly fixed to the DIN rail in order to ensure air supply without leakage










Insert pins after removing the connectorfrom the main unit. After inserting pins, lightly pull lead wires to check that the pins are locked.



SV

SZ

SYJ

SX

Note) Insert tab terminals completely.

Fitting Assembly

Type 45 manifold permits change in the A and B port sizes by changing the manifold block fitting assembly.

After removing the valve, remove the clip with a screwdriver, etc. For mounting a new fitting assembly, insert it and then insert a clip until it will not come out of the manifold block.

Fitting Assembly Part No.

Matric siza

	,. <u>_</u>	
SY3000	One-touch fitting for ø4	VVQ1000-50A-C4
513000	One-touch fitting for ø6	VVQ1000-50A-C6
	One-touch fitting for ø4	VVQ1000-51A-C4
SY5000	One-touch fitting for ø6	VVQ1000-51A-C6
	One-touch fitting for ø8	VVQ1000-51A-C8

Inch size

evanno	One-touch fitting for ø5/32"	VVQ1000-50A-N3
513000	One-touch fitting for ø ⁵ / ₃₂ " One-touch fitting for ø ¹ / ₄ "	VVQ1000-50A-N7
	One-touch fitting for ø5/32"	VVQ1000-51A-N3
	One-touch fitting for ø 1/4"	VVQ1000-51A-N7
	One-touch fitting for ø5/16"	VVQ1000-51A-N9

Note 1) P and R ports cannot be changed. Note 2) Use caution that O-rings must be free from scratches and dust. Otherwise, air leakage may result.

