

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2000180-4  
**Report Reference** MH11419-20200517  
**Date** 2-Aug-2021

**Issued to:** SMC CORP  
TSUKUBA TECHNICAL CENTER  
4-2-2 KINUNODAI TSUKUBAMIRAI-SHI, IBARAKI-KEN  
Japan 300-2493

**This is to certify that representative samples of** YIOZ - Valves, Electrically Operated  
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 429, 7th Ed., Issue Date: 2013-11-06, Revision Date: 2021-03-19

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2000180-4  
**Report Reference** MH11419-20200517  
**Date** 2-Aug-2021

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

| <b>Model</b>   | <b>Category Description</b> |
|--|-----------------------------|
| F1-JSX, followed by 2 or 3, followed by 1, followed by S, followed by N, followed by 301, 302, 303, 402, 403, 502, 503, 702 or 703, followed by F, N or R, followed by 1, 2, 3, 4, 5, 6, 7, 8, B or J, followed by CS, followed by D or V, with or without B.          | General-purpose valve       |
| HF3-JSX, followed by 2 or 3, followed by 1, followed by S, followed by N, followed by 301, 302, 303, 402, 403, 502, 503, 702 or 703, followed by F, N or R, followed by 1, 2, 3, 4, 5, 6, 7, 8, B or J, followed by CS, followed by D or V, with or without B.         | General-purpose valve       |
| JSX, followed by 2 or 3, followed by 1, followed by S, followed by E, F or N, followed by 301, 302, 303, 402, 403, 502, 503, 702 or 703, followed by F, N or R, followed by 1, 2, 3, 4, 5, 6, 7, 8, B or J, followed by CS, with or without D or V, with or without B. | General-purpose valve       |



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

