## Fieldbus system

# **Operation Manual**



DeviceNet₁

Thank you for purchasing an SMC EX600 Series Fieldbus system. Please read this manual carefully before operating the product and make sure you understand its capabilities and limitations

Please keep this manual handy for future reference.

To obtain more detailed information about operating this product, please refer to the SMC website (URL http://www.smcworld.com) or contact SMC directly.

### Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage

These instructions indicate the level of potential hazard with the labels of "Caution", "Warning" or "Danger". They are all important notes for safety and must be followed in addition to International standards (ISO/IEC), Japan Industrial Standards (JIS) and other safety regulations.

⚠ Caution: CAUTION indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.

↑ Warning: WARNING indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.

**■**Safety Instructions

■ Do not operate the product outside of the specifications.

Do not use for flammable or harmful fluids.

Fire, malfunction, or damage to the product can result Verify the specifications before use.

This product is not designed to be explosion proof.

\*Check the product regularly for proper operation.

Otherwise malfunction can result, causing an accident

maintenance.
Otherwise an injury can result

■NOTE

⚠ Danger: DANGER indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury.

#### Operator

◆ This operation manual is intended for those who have knowledge of machinery using pneumatic equipment, and have sufficient knowledge of assembly, operation and maintenace of such equipment. Only those persons are allowed to perform assembly, operation and maintenance.

**⚠** Warning

■ Do not disassemble, modify (including changing the printed circuit board) or repair. An injury or failure can result.

■The following instructions must be followed during maintenance:
-Turn off the power supply.
-Stop the air supply, exhaust the residual pressure and verify that the air is released before performing

**△** Caution

•The direct current power supply to combine should be UL1310 Class2 power

For heavy stains, use a cloth soaked with diluted neutral detergent and fully squeezed, then wipe up

Refer to the SMC website (URL <a href="http://www.smcworld.com">http://www.smcworld.com</a>) to obtain more detailed

■ Do not operate in an atmosphere containing flammable or explosive gases.

Fire or an explosion can result

■When handling the unit or assembling/replacing units:

-Do not touch the sharp metal parts of the connector or plug for connecting units.

-Take care not to hit your hand when disassembling the unit.

-The connecting portions of the unit are firmly joined with seals.

-When joining units, take care not to get fingers caught between units.

An injury can result.

After maintenance is complete, perform appropriate functional inspections. Stop operation if the equipment does not function properly.

■ Provide grounding to assure the safety and noise resistance of the Fieldbus system. Individual grounding should be provided close to the product with a short cable.

Maintenance should be performed according to the Safety Instructions.

Do not use solvents such as benzene, thinner etc. to clean each unit. They could damage the surface of the body and erase the markings on the body.

Safety cannot be assured in the case of unexpected malfunction.

supply when conformity to UL is necessary

•Perform regular maintenance and inspections.
There is a risk of unexpected malfunction.

Maintenance

Use a soft cloth to remove stains.

information about maintenance


■If using the product in an interlocking circuit:

•Provide a double interlocking system, for example a mechanical system.

◆ Read and understand this operation manual carefully before assembling operating or providing maintenance to the product.

### Names and Functions of Product

#### ONames of individual parts





No.	Description	Function
1	Status display LED	Displays the status of the unit.
2	Display cover	Open for the setting of switch.
3	Display cover tightening screw	Loosen to open the display cover.
4	Connector (BUS OUT)	Connects the cable for fieldbus outputs.
5	Marker groove	Groove to mount a marker.
6	Connector (PCI)	Connects the cable of the handheld terminal.
7	Valve plate mounting screw hole	Fixes the valve plate.
8	Valve plate mounting groove	Groove to insert the valve plate into.
9	Joint bracket	Bracket for joining to adjacent units.
10	Unit connector (plug)	Transmits signals and power supplies to adjacent units.
11	Connector (BUS IN)	Connects the cable for fieldbus inputs.
12	Seal cap (2 pcs.)	Mounted on to unused connectors. (BUS OUT and PCI)

### **Assembly**

#### O Composing the unit as a manifold


(1)Connect the unit to the end plate.

The Digital unit, Analog unit can be connected in any order Tighten the bracket of the joint using tightening torque


(2)Add more units. Up to 10 units (including the SI unit) can be connected to one manifold.

After connecting the necessary units, connect the SI unit. Connecting method is the same as above (1), (2).

(4) Mounting the valve plate. Mount the valve plate (EX600-ZMV□) to the valve manifold using the valve set screws. (M3x8) Apply 0.6 to 0.7 Nm tightening torque to the screws.



(5)Connect the SI unit and the valve manifold. Insert the valve plate to the valve plate set groove on the side of SI unit. Then, tighten it with the valve plate set screws (M4x6) to fix the plate. Tightening torque for set screws 0.7



### **Mounting and Installation**

### ■Installation

#### Direct mounting

(1)When joining six or more units, fix the middle part of the complete EX600 unit with an intermediate reinforcing brace (EX600-ZMB1) before mounting using 2-M4x5 screws. Tightening torque: 0.7 to 0.8 Nm.


(2) Fix and tighten the end plates at one end of the Tightening torque: 0.7 to 0.8 Nm.

Fix the end plate at the valve side while referring to the operation manual of the corresponding

•DIN rail mounting

(Available for series other than SY series, Refer to the catalog for SY series.) (1)When joining six or more units, fix the middle


part of the complete EX600 unit with an intermediate reinforcing brace (EX600-ZMB2) pefore mounting, using 2-M4x6 screws Tightening torque: 0.7 to 0.8 Nm.



(EX600-ZMB1)


(2)Mount the end plate bracket (EX600-ZMA2) to the end plate at the opposite end to the valves, using 2-M4x14

Tightening torque: 0.7 to 0.8 Nm.




Intermediate reinforcing brace

(3) Hook the DIN rail mounting groove to the DIN rail.



(4) Press the manifold using its side hooked to the DIN rail as a fulcrum until the manifold is locked



(5)Fix the manifold by tightening the DIN rail fixing screws of the EX600-ZMA2. (M4x20) Tightening torque: 0.7 to 0.8 Nm.

The tightening torque at the valve side depends on

the valve type. Refer to the operation manual of the corresponding

#### ■Wiring


valve manifold.

•Connect the M12 connector cable, M12 connector is applicable for SPEEDCON

connector.
SPEEDCON connector wiring method is explained below.
(1)Align the mark B on the metal bracket of the cable side connector (plug/socket) with

(2) Align the mark C on the unit and insert the connector into the unit vertically. If they are not aligned, the connector cannot be joined properly.

(3)When the mark B of the connector has been turned 180 degrees (1/2 turn), wiring is completed. Confirm that the connection is not loose. If turned too far, it will become hard to remove the connector




#### •Connector pin assignment

Configu	Pin number	Signal name	
BUS IN	BUS IN BUS OUT		Oignai name
2 _ 1		1	DRAIN
	1002	2	V+
$\left( \left( \begin{smallmatrix} 0 \\ 50 \end{smallmatrix} \right) \right) \left( \left( \begin{smallmatrix} 0 \\ 50 \end{smallmatrix} \right) \right)$	(50)	3	V-
	403	4	CAN_H
3 4		5	CAN_L

Mounting the marker

Signal name of the input or output devices and unit address can be written to the marker, and it can be installed to each unit.

Mount the marker (EX600-ZT1) into the marker groove as required.



## **Setting and Adjustment**











#### Address setting switch

Address X10	Address X1	Node Address
0	0	0 (Default setting)
0	1	1
:	:	:
6	3	63
6	4	
:	:	PGM
9	9	

#### •Data Rate setting switch

Communication speed	
125 kbps (Default setting)	
250 kbps	
500 kbps	
PGM	

#### •V\_SEL switch: The number of outputs (size) occupied by the SI unit is selected.

Settings1		Content	SI unit output data size	
1	2	Content	31 unit output data size	
OFF	OFF	Number of occupied valve 32 outputs	4 byte (Default setting)	
OFF	ON	Number of occupied valve 24 outputs	3 byte	
ON	OFF	Number of occupied valve 16 outputs	2 byte	
ON	ON	Number of occupied valve 8 outputs	1 byte	
-	-			

·Switch for diagnosis: Allocates the diagnostic data to the input data

Sett	ings2	Mode	Content	Diagnostic size set for
1	2	IVIOGE	Content	the input
OFF	OFF	0	Input data only (Default setting) 0 byte	
OFF	ON	1	Input data + System diagnosis 4 byte	
ON	OFF	2	Input data + System diagnosis + Unit diagnosis (Up to 10 units) 6 byte	
LIOLD/OLEAD soutch, Oats the soutcut status when the Fieldhood has a communication array or in in idline state				

+HOLD/CLEAR switch: Sets the output status when the Fieldbus has a communication error or is in idling state.

Settings2	Content	
3		
OFF	Output is Off. (Default setting)	
ON Holds the output.		
HW/SW switch: Select the selection me		

thod of the Fieldbus address and Data Bate

Settings2	Content			
4	Content			
OFF	Address and Data Rate are set by the SI unit switch. (Hardware) (Default setting)			
ON	Address and Data Rate are set via the PLC. (Software) *			

<sup>:</sup> In order to set software via PLC, set the address or Data Rate switch to PGM

Refer to the SMC website (URL <a href="http://www.smcworld.com">http://www.smcworld.com</a>) to obtain more detailed information about setting and adjustment.

### **LED Display**

The status display LED displays the power supply and communication status.

MC	SI	Display
M) PWR PWR(V) MS NS		ST(M)
x10 x1	$\neg \parallel$	PWR
ngs1 "Address" Date F	tate	PWR(V)
Settings2		MS
Desice	Vet	NS


Display	Content		
ST(M)	Displays the diagnosis status of the unit.		
PWR	Displays the status of the power supply voltage for control and input.		
PWR(V)	Displays the status of the power supply voltage for outputs.		
MS	Displays the module status.		
NS	Displays the network status.		

#### ·SI unit common status

LED display	Content
ST(M) PWR PWR(V) OOO Off	The power supply for control and input is Off.
ST(M) PWR PWR(V)  Green LEDs are On	The unit is in normal operation.
ST(M) PWR PWR(V)	A component failure inside the SI unit.
ST(M) PWR PWR(V) O ● O  Red PWR LED is On	The power supply voltage for control and input is abnormal.
ST(M) PWR PWR(V)	The power supply voltage for output is abnormal.
ST(M) PWR PWR(V)  Green ST(M) LED is flashing	A unit other than the SI unit has been diagnosed and detected.
ST(M) PWR PWR(V)  CO  Red ST(M) LED is flashing	Either of the following conditions: •The valve On/Off counter has exceeded the set value. •The valve is short circuited or disconnected.
ST(N) PWR PWR(V)  Red/green ST(M) LED is flashing alternately	Connection error between units occurred.

#### DeviceNet<sup>™</sup> status

LED display	Content
MS NS O O Off	The power supply for control and input is Off.
MS NS  Creen MS LED is On	*Double checking the node address. *Communication error.
MS NS	Communication is normal.
MS NS Green MS LED is On and green NS LED is flashing	Connection is not established.
MS NS	The element in SI unit is broken.
MS NS	Fatal communication error.



Refer to the SMC website (URL http://www.smcworld.com) to obtain more detailed information about LED display

### Troubleshooting

Refer to the LED Display. Refer to the SMC website (URL http://www.smcworld.com) to obtain more detailed information about troubleshooting.

#### Specification

	Power supply	Control and input	24 VDC Class2, 2 A
		Output	24 VDC Class2, 2 A
ı	Connected load		Solenoid valve with lamp and circuit of protection of surge voltage of 24 VDC 1.5 W (SMC)
Operating temperature range		temperature range	-10 to 50 °C (Max. surrounding air temperature rating: 50 °C)
ı	Storage temperature range		-20 to 60 °C
ı	Poll	ution degree	For use in Pollution Degree 2 Environment (UL508)
	Vibration resistance		10 to 57 Hz: constant amplitude 0.75 mm p-p 57 to 150 Hz: constant acceleration 49 m/s <sup>r</sup> for 2 hours each in direction X, Y and Z respectively (De-energized)
I	Impact resistance		147 m/s² 3 times each in directions of X, Y and Z respectively (De-energized)

Refer to the product catalog or SMC website (URL http://www.smcworld.com) to obtain more detailed information about product specifications.

#### Commissioning

•Parameter Setting •Hardware Configuration (EDS file) •I/O Map •Diagnostic •DeviceNet™ Object

Refer to the SMC website (URL http://www.smcworld.com) to obtain more detailed information about these setting above.

### **Outline with Dimensions**

Refer to the product catalog or SMC website (URL http://www.smcworld.com) to obtain more detailed information about outline dimensions.

SMC Corporation URL http://www.smcworld.com

Akihabara UDX 15F, 4-14-1, Sotokanda, Chiyoda-ku, Tokyo 101-0021, JAPAN Phone: +81 3-5207-8249 Fax: +81 3-5298-5362

Note: Specifications are subject to change without prior notice and any obligation on the part of the manufacturer DeviceNet™ is a trademark of ODVA. © 2009 SMC Corporation All Rights Reserved